

DECLARATION OF PERFORMANCE



No. 921164200_59_003

1. Unique identification code of the product-type: BS-1642
2. Intended use/es: 12 zones conventional fire alarm control panel for use in fire detection and fire alarm systems installed in buildings.
3. Manufacturer: Olympia Electronics N. Lakasas – P. Arvanitidis S.A. 72nd klm Old national road Thessaloniki – Katerini, Kolindros, Pieria, Greece P.O. 60061
4. System/s of AVCP: System 1
5. Harmonized standard: EN 54-2:1997 +A1:2006 Fire detection and fire alarm systems – Part 2: Control and indicating equipment

EN 54-4: 1997 +A1:2002 +A2:2006 Fire detection and fire alarm systems – Part 4: Power supply equipment

Notified body/ies: EVPÚ a.s., No. 1293

6. Declared performance/s:

Essential characteristics	Performance	Harmonised technical specification:		
		EN 54-2:1997 +A1:2006	EN 54-4:1997 +A1:2002 +A2:2006	Comments
Operational reliability	PASS	4 ^a , 5 ^a , 6 ^a , 7 ^a , 8 ^a , 9 ^a , 10 ^a , 11=N/A, 12 ^a , 13 ^a , 14 ^a	4 ^b , 5 ^b , 6 ^b , 7 ^b , 8 ^b	a, b
Durability of operational reliability: Temperature resistance	PASS	15.4	9.5	
Durability of operational reliability: Vibration resistance	PASS	15.6, 15.7, 15.15	9.7, 9.8, 9.15	
Durability of operational reliability: Humidity resistance	PASS	15.5, 15.14	9.6, 9.14	
Durability of operational reliability: Electrical stability	PASS	15.8, 15.13	9.9	
Response delay (response time to fire)	PASS	7.1, 7.7, 7.11, 7.12=N/A	-	a
Performance under fire conditions	PASS	4, 5, 7	-	a, b
Performance of power supply	PASS	-	4, 5, 6	b

Comments:

a) The product has been certified with the available options with requirements of the harmonized technical specification **EN 54-2:1997 +A1:2006** which are mentioned below.

7.8 Output to fire alarm devices

7.11 Delay to outputs

7.12 Co-incident

7.13 Alarm counter

10 Test condition

b) The product covered by the standards that are mentioned above is assumed to function during the alarm condition, in an event of fire, before the fire becomes as large as to affect its functioning. There is therefore no requirement to function when exposed to direct attack from fire.

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

OLYMPIA ELECTRONICS
ELECTRONIC MANUFACTURERS
N. LAKASAS - P. ARVANITIDIS S.A.
60061 KOLINDROS - GREECE
TEL: 0030 23530 51200 - 51611 - 51612
FAX: 0030 23530 51486
ATHENS TEL: 0030 210 9852193-4
FAX: 0030 210 9852225



Olympia Electronics
Product Validation Department

Kolindros, Pieria, Greece at 16/5/2016

Tyropoli Antrianna, Product Validation Department