

GR-900/30L/SC Waterproof self-testing maintained emergency luminaire



TECHNICAL CHARACTERISTICS

OPERATION VOLTAGE	220-240V AC/50-60Hz
MAXIMUM POWER CONSUMPTION	7W / 7.5VA /PF: 0.93
BACK UP SOURCE	Ultra Capacitor A-900
CAPACITOR PROTECTION	From overcharge
INDICATIONS - CONTROLS	CHARGE, LAMP FAULT, BAT FAULT, TEST button
CHARGING TIME	3h
MINIMUM AUTONOMOUS DURATION	60 min
ILLUMINATION SOURCE	White LED's
LIGHT SOURCE INTENSITY	210lm (230V AC) / 80lm (emergency)
DEGREES OF COVER PROTECTION	IP 65
PRODUCED IN ACCORDANCE WITH	EN 60598-1, EN 60598-2-22, EN 55015, EN 61547, EN 61000-3-2, EN 61000-3-3
OPERATION TEMPERATURE RANGE	-30 to +50 °C
RELATIVE HUMIDITY	Up to 95%
EXTERNAL DIMENSIONS (L x W x H)	363 x 145 x 73 mm
TYPICAL WEIGHT	1055gr.
GUARANTEE	5 years

Thank you for purchasing this product of Olympia Electronics. A European manufacturer.

GENERAL

This luminaire is used in places where emergency luminaires are needed.

Each luminaire must be permanently connected to mains power supply.

In normal operation the led strip lights and the capacitor is charging.

In case of a mains power supply failure the luminaire will light the led strip automatically in emergency mode. When the mains power supply is restored the device turns to normal operation.

INSTALLATION

To install the luminaire follow the installation instructions on page 3.

Capacitor charging

The capacitor charging is completely and accurately controlled. In this case, is achieved the perfect capacitor maintenance, as well as the elongation of its duration. When the capacitor has completely charged, it charges with a maintenance current.

Capacitor Cut-off

The luminaire enters in this operation when the mains power supply fails and capacitor has lost its energy. During this operation the luminaire enters the idle state and the capacitor's consumption is negligible.

Manual Test

The manual test can be conducted only if the

main power supply and the capacitor is connected. By pressing the TEST/RESET button briefly (page 3) an emergency operation test is initiated. During this test period all indication LEDs are OFF and the whole emergency circuit is monitored.

Automatic test

This test includes all the operations that provide the manual test and is conducted automatically every 15 days. In order to be performed, the main power supply and the capacitor should be connected.

Manual Autonomous Test

If the Test button is pressed for a period between 5 to 10 seconds (with the capacitor fully charged), the illumination sign will enter in counting autonomy condition. *If the capacitor is not fully charged this command is ignored.*

The BAT FAULT LED blinks during the measurement, indicating this process to the user. This measurement duration is equal with the nominal autonomous duration of the luminaire and at the end of the process, if the measured duration was at least the nominal autonomous duration, the BAT FAULT LED is turned OFF, in the other hand stays continuously ON indicating to the user that the capacitor must be replaced.

Automatic Autonomous Test

The Automatic autonomous Test is conducted and measures the luminaire's sign's back up operation and emergency duration. This test is conducted automatically every six months. In order to be performed, the main power supply

and the capacitors should be connected and fully charged. If the capacitor is not fully charged, the test is postponed until the capacitor is completely charged.

Back Up Operation

The capacitor's autonomous duration during emergency mode is at least the one that is stated in the list of the technical characteristics. During emergency mode, a LED strip test is also performed.

Resetting Errors

Push the TEST/RESET button (page 3) for >10 seconds, to delete all the indicated LED errors. Then the illumination sign enters regular operation mode.

Test switch

Pressing the test switch less than 5 seconds will initiate a light source test (last for 3 secs).

Pressing the test switch between 5 to 10 seconds will initiate a manual capacitor duration test. This test will not be started if the capacitor is not fully charged (i.e. If the green LED is flashing). If the test switch is pressed

for more than 10 seconds, the illumination sign will be reset (delete all errors).

LABELING EXPLANATION:

X: Self contained

1: Maintained

A: Including test device

***60: 1 hour duration**

ATTENTION!!!

1. Operations for installation, maintenance or testing must be done by authorized personnel only.

2. The luminaire must be connected to the mains power supply thru a fuse dependent by the total amount of the line's power load.

3. In case of capacitors or lamp replacement, these must be replaced by parts of the same type, by the manufacturer or by a competent person.








4. **It is not allowed to discard batteries in to common trash bins, they must be discarded only in battery recycling points. Do not incinerate.**



Status of LEDs

LEDs			Description
GREEN	YELLOW	RED	
<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Normal
<input checked="" type="radio"/>	<input type="radio"/>	<input type="radio"/>	Charging
<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	Charger's fault, capacitor not connected or mains off
<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Capacitor's duration test (auto or manual)
<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Capacitor's fault
<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	Light source test
<input checked="" type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	Light source fault
<input checked="" type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	Capacitor's fault and light source fault
<input type="radio"/>	<input checked="" type="radio"/>	<input type="radio"/>	Charger and capacitor's fault (or mains off and battery fault)
<input type="radio"/>	<input type="radio"/>	<input checked="" type="radio"/>	Charger and light source fault (or mains off and light source fault)
<input type="radio"/>	<input checked="" type="radio"/>	<input checked="" type="radio"/>	Charger, capacitor and light source fault (or mains off, capacitor and light source fault)
Led status explanation			
<input checked="" type="radio"/>	Continuous ON	<input type="radio"/>	Continuous OFF
<input checked="" type="radio"/>		<input checked="" type="radio"/>	Flashing at 1,2 Hz

INSTALLATION INSTRUCTIONS



For wall or ceiling installation

Step 1. Remove the diffuser. Place simultaneously 2 flat blade screwdrivers and pull up gently the reflector.

Step 2. Install the included plastic cover in to the unused hole and install the base plastic (with the included mounting screws and plugs).

Step 3. Always use in any case round mains cable, with external diameter of 6-9mm (H05RN-F type 2x1mm² or any other type, at least equal to it's mechanical and electrical properties). **ATTENTION!!** The cable must not be deformed in any way (This requirement is important to ensure the tightness isolation IP 65). Install the cable gland, pass the round cable thru and tighten it all the way.

Step 4. Place the capacitor's connector to the corresponding connector on the P.C.B.

Step 5. Connect the mains cables to the respective terminal block (connect the ground wire if required). N for neutral, L for live wire and L1 for the maintained operation. The L1 wire can be connected to an external switch to control the maintained or non maintained operation of the luminaire. For permanent maintained operation use two wires to power the luminaire, N for neutral and L for live wire, and link the L and L1.

Step 6. Install the included tie (if needed) to fasten securely the power cables.

Step 7. Refit the reflector and fasten the two small screws (included).

Step 8. Finally place the diffuser by using the 4 screws (tightening torque 1.2Nm).

Step 9. Manual TEST or Resetting Errors

In order to test or reset the device you must carefully remove the diffuser by unfastening the 4 mounting screws. Then push the button as described in the according paragraphs on page 1 and 2.

NOTE!!

After finishing the installation you must power the luminaire at least for 3 hours for capacitor charging to perform the named autonomy.

Battery replacement.

It can be done only by a competent person and after the mains interruption.

1. Unfasten the 4 screws (step 8 page 3) and remove the diffuser. Unfasten the 2 retaining screws and remove the reflector (step 7 page 3).
2. Disconnect the connector and remove the old capacitor pack by untastening the retaining screws (S) .
3. Connect the new capacitor pack (step 4 of the installation procedure) place it in the position of the old one and fasten the removed screws.
4. Refit the removed parts in previous steps and power the device.



Important notice for the installed luminaires in one area !!!

The installer must connect the capacitor's connector first and then should power the luminaire. The capacitor connection must have at least a time variation of 1.5 minute for each luminaire. With this variation, it is ensured that the non synchronized Automatic Autonomous Test for two or more luminaires installed in one area, is not conducted in the same day.